

DISTRICT LEVEL WATER TESTING LABORATORY **P.H.DIVISION, MADHUBANI**

Sample Collected & Submitted by- Dr. Binod

Sampling Date:- 10/03/2025
Testing Date:- 11/03/2025
Months:- March 2025

Sl No.	Block	Panchayat	Village	Source of Water	Name of Location/Nearst Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	Remarks
1	Madhwapur	Saharghat	Saharghat	Hand Pump	M.G.M Senior Secondary School	7.8	2.1	188	217	46.5	16.6	35	0.3	BDL	00	BDL	410	630	NT	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5 - 1.5	200 - 400	45	500 - 2000		0.01- NR	

*NT - Not Tested
*BDL- Below Detection Limit

NOTE:- THIS REPORT IS VALID FOR 6 MONTHS FROM THE DATE OF TESTING.

[Signature]
11/03/25
Lab Assistant
District Laboratory, Madhubani

CHEMIST
P.B.B.D. Madhubani
[Signature]
11/3/25
Chemist
District Laboratory, Madhubani